



SECTION THROUGH
SHAFT EXTENSION.
(SCALE 1:4).

NOTE!
TERMINAL BOX CAN BE MOUNTED (LEFT OR RIGHT) BY REFITTING FEET AND LIFTING LUGS 90° IN APPROPRIATE DIRECTIONS. CABLE ENTRY CAN BE SUPPLIED IN ANY ONE OF FOUR POSITIONS AT 90° INTERVALS.

CUSTOMER	
ORDER No.	
SERIAL No.	
FRAME SIZE	
KW	R.P.M.
Hz	PHASE 3
VOLTS	POLES
BRGS.	D.E. N.D.E
MOTOR NETT. WT.	Kg.
INSULATION CLASS	
TEMPERATURE RISE °C	
DESIGN AMBIENT TEMPERATURE °C	
HEATER WATTS & VOLTS (IF FITTED)	
- WATTS, - VOLTS	

REMARKS

EEx d IIB
BASEEFA CERTIFICATE
No. Ex99E1170X.

ALL DIMENSIONS IN MILLIMETRES

FIRST ANGLE PROJECTION

NOTE!
2.5 ENDPLAY WILL BE PROVIDED FOR ENDTHRUST PROTECTION WHEN CUSTOMERS NOTIFY US OF THEIR INTENTION TO USE RIGID COUPLINGS AND DRIVEN MACHINES WITHOUT ENDPLAY.

OUTLINE DIMENSIONS OF STANDARD FOOT MOUNTED METRIC A.C MOTOR TO BS4999 PART 141. EEx d TO EN50014/18.
TOTALLY ENCLOSED FA N VENTILATED.
FRAME SIZE: W-EF315M (4 POLE UP).

SCALE	1/8	DATE
DRAWN	M.E	6.1.00
CHECKED	J.M.L	6.1.00
APPROVED	J.M.L	6.1.00

DRG. No.	M70219	
REVISION:		DATE