



SECTION THROUGH SHAFT EXTENSION. (SCALE 1:4).

NOTE!
 TERMINAL BOX CAN BE MOUNTED (LEFT OR RIGHT) BY REFITTING FEET AND LIFTING LUGS 90° IN APPROPRIATE DIRECTIONS. CABLE ENTRY CAN BE SUPPLIED IN ANY ONE OF FOUR POSITIONS AT 90° INTERVALS.

CUSTOMER		
ORDER No.		
SERIAL No.		
FRAME SIZE		
Kw	R.P.M.	
Hz	PHASE 3	
VOLTS	POLES	
BRGS.	D.F.	N.D.F.
MOTOR NETT. WT.	Kg.	
INSULATION CLASS		
TEMPERATURE RISE °C		
DESIGN AMBIENT TEMPERATURE °C		
HEATER WATTS & VOLTS (IF FITTED)		
- WATTS, - VOLTS		

REMARKS

EEx de IIB
 BASEEFA CERTIFICATE
 No. Ex99E1171X.

or

EEx de IIC
 BASEEFA CERTIFICATE
 No. Ex99E1172X.

ALL DIMENSIONS IN MILLIMETRES

FIRST ANGLE PROJECTION

NOTE!
 2.5 ENDPLAY WILL BE PROVIDED FOR ENDTHRUST PROTECTION WHEN CUSTOMERS NOTIFY US OF THEIR INTENTION TO USE RIGID COUPLINGS AND DRIVEN MACHINES WITHOUT ENDPLAY.

OUTLINE DIMENSIONS OF STANDARD FOOT MOUNTED METRIC A.C MOTOR TO BS4999 PART 141. EEx de TO EN50014/18/19. TOTALLY ENCLOSED FA N VENTILATED. FRAME SIZE: W-EF315S (4 POLE UP).

SCALE	1:8	DATE	DRG. No.
DRAWN	LM	6.1.00	M70223
CHECKED	J.M.L	6.1.00	-
APPROVED	J.M.L	6.1.00	REVISION: DATE