



NOTE:-  
CABLE ENTRY CAN BE  
SUPPLIED IN ANY ONE OF FOUR  
POSITIONS AT 90° INTERVALS.

NOTE1  
STANDARD MACHINES ARE ARRANGED FOR HORIZONTAL OVERHUNG MOUNTING.  
CUSTOMERS SHOULD NOTIFY US WHEN ORDERING IF VERTICAL MOUNTING  
IS REQUIRED. IF VERTICAL, THE MOTOR THRUST BEARING MUST  
NOT BE ALLOWED TO TAKE ANY LOAD OTHER THAN THE WEIGHT OF  
THE ROTOR WITHOUT OUR APPROVAL.

CUSTOMER	
ORDER No.	
SERIAL No.	
FRAME SIZE	
KW	R.P.M.
Hz	PHASE 3
VOLTS	POLES
BRGS.	D.E. N.D.E
MOTOR NETT. WT.	Kg.
INSULATION CLASS	
TEMPERATURE RISE °C	
DESIGN AMBIENT TEMPERATURE °C	
HEATER WATTS & VOLTS (IF FITTED)	
- WATTS, - VOLTS	

REMARKS

**BROOK CROMPTON**  
PRELIMINARY

Large Industrial Motors  
Guisley, LEEDS LS20 9NZ

ALL DIMENSIONS IN INCHES

THIRD ANGLE PROJECTION

**BROOK CROMPTON**

Large Industrial Motors  
GUISLEY, LEEDS, LS20 9NZ.

NOTE1  
ENDPLAY WILL BE PROVIDED FOR ENDTHRUST PROTECTION WHEN CUSTOMERS NOTIFY US OF THEIR INTENTION TO USE RIGID COUPLINGS AND DRIVEN MACHINES WITHOUT ENDPLAY.

OUTLINE DIMENSIONS OF STANDARD FLANGE MOUNTED INCH A.C MOTOR TO NEMA STD. MG1. TOTALLY ENCLOSED FAN VENTILATED. TERMINAL BOX MOUNTED ON LEFT HAND SIDE VIEWED ON DRIVE END. FRAME SIZE. W-DF324TSD-X (2 POLE ONLY).

SCALE	1:6	DATE
DRAWN	M.E	19.8.99
CHECKED	J.M.L	19.8.99
APPROVED	J.M.L	19.8.99

DRG. No.	M21647
REVISION:	DATE