



ENLARGED VIEW OF
SHAFT EXTENSION.
(SCALE 1:2.)

NOTE: -
STANDARD MACHINES ARE ARRANGED FOR HORIZONTAL OVERHUNG MOUNTING. CUSTOMERS SHOULD NOTIFY US WHEN ORDERING IF VERTICAL MOUNTING IS REQUIRED. IF VERTICAL, THE MOTOR THRUST BEARING MUST NOT BE ALLOWED TO TAKE ANY LOAD OTHER THAN THE WEIGHT OF THE ROTOR WITHOUT OUR APPROVAL.

| | | |
|----------------------------|---------|--------------|
| CUSTOMER | | |
| ORDER No. | | |
| SERIAL No. | | |
| FRAME SIZE | | |
| kW | RPM. | |
| Hz | PHASE 3 | |
| VOLTS | POLES | |
| BRGS. | DE. | NDE. |
| MOTOR NETT. WT. | | Kg. |
| INSULATION CLASS | | |
| TEMPERATURE RISE | | °C |
| DESIGN AMBIENT TEMPERATURE | | °C |
| HEATER WATTS & VOLTS | | WATTS, VOLTS |

REMARKS

FITTED WITH FLARED CABLE ENTRY.

BROOK CROMPTON
PRELIMINARY

Large Industrial Motors
Guiseley, LEEDS LS20 9NZ

ALL DIMENSIONS IN INCHES

THIRD ANGLE PROJECTION

BROOK CROMPTON

Large Industrial Motors
GUISELEY, LEEDS, LS20 9NZ.

NOTE 1
2.5 ENDPLAY WILL BE PROVIDED FOR ENDTHRUST PROTECTION WHEN CUSTOMERS NOTIFY US OF THEIR INTENTION TO USE RIGID COUPLINGS AND DRIVEN MACHINES WITHOUT ENDPLAY.

OUTLINE DIMENSIONS OF STANDARD FLANGE MOUNTED INCH A. C. MOTOR TO NEMA STANDARD MG1. TOTALLY ENCLOSED FAN COOLED. SIDE MOUNTED TERMINAL BOX.
FRAME SIZE: W-DF444TD-E (2 POLE ONLY.)

| | | |
|----------|-------|--------|
| SCALE | 1:8 | DATE |
| DRAWN | M.E | 4.7.00 |
| CHECKED | J.M.L | 4.7.00 |
| APPROVED | J.M.L | 4.7.00 |

| | |
|-----------|--------|
| DRG. No. | M22076 |
| REVISION: | DATE |